

Issuance Date: September 23, 2005
Mod 1 Date: May 3, 2006
Effective Date: May 15, 2006
Expiration Date: September 23, 2010

STATE WASTE DISCHARGE PERMIT Number ST-6204

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

In compliance with the provisions of the
State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington, as amended,
and
the Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1251 et seq.,
authorizes

Ocean Protein, LLC
P.O. Box 696, 518 22nd Street
Hoquiam, WA 98550

Facility Address:

P.O. Box 696
518 22nd Street
Hoquiam, WA 98550

Discharge Location:

Latitude: 46° 58' 03" N
Longitude: 123° 51' 45" W

Treatment Works Receiving Discharge:

Grays Harbor Paper, L.P.
801 23rd Street
Hoquiam, WA 98550

Industry Type: Fish meal processing plant

SIC Code: 2077

to discharge wastewater in accordance with the special and general conditions which follow.

Merley F. McCall
Industrial Section Supervisor
Washington State Department of Ecology

TABLE OF CONTENTS

SUMMARY OF PERMIT REPORT SUBMITTALS.....4

SPECIAL CONDITIONS

S1. DISCHARGE LIMITATIONS5

S2. MONITORING REQUIREMENTS6

 A. Wastewater Monitoring

 B. Sampling and Analytical Procedures

 C. Flow Measurement

 D. Laboratory Accreditation

S3. REPORTING AND RECORDKEEPING REQUIREMENTS7

 A. Reporting

 B. Records Retention

 C. Recording of Results

 D. Additional Monitoring by the Permittee

 E. Noncompliance Notification

 F. Spill Notification

 G. Maintaining a Copy of This Permit

S4. OPERATION AND MAINTENANCE9

 A. Bypass Procedures

 B. Best Management Practices\Pollution Prevention Program

S5. PROHIBITED DISCHARGES10

 A. General Prohibitions

 B. Specific Prohibitions

 C. Prohibited Unless Approved

S6. DILUTION PROHIBITED11

S7. SOLID WASTE DISPOSAL11

 A. Solid Waste Handling

 B. Leachate

 C. Solid Waste Control Plan

S8. DUTY TO REAPPLY12

S9. NON-ROUTINE AND UNANTICIPATED DISCHARGES.....12

S10.	SPILL PLAN.....	13
S11.	SLUG DISCHARGE CONTROL PLAN	13
S12.	RECORDS OF WASTE TRANSPORTED OFF-SITE	14

GENERAL CONDITIONS

G1.	SIGNATORY REQUIREMENTS.....	15
G2.	RIGHT OF ENTRY	15
G3.	PERMIT ACTIONS	16
G4.	REPORTING A CAUSE FOR MODIFICATION.....	16
G5.	PLAN REVIEW REQUIRED.....	16
G6.	COMPLIANCE WITH OTHER LAWS AND STATUTES	16
G7.	PERMIT TRANSFER	16
G8.	REDUCED PRODUCTION FOR COMPLIANCE	17
G9.	REMOVED SUBSTANCES.....	17
G10.	PAYMENT OF FEES	17
G11.	PENALTIES FOR VIOLATING PERMIT CONDITIONS	17

SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.A.	Discharge Monitoring Report	Monthly	First month after permit effective date
S4.B.	Best Management Practices/Pollution Prevention Plan	1/permit cycle	180 calendar days after permit effective date
S7.C.	Solid Waste Control Plan	1/permit cycle	180 calendar days after permit effective date
S8.	Duty to Reapply	1/permit cycle	60 calendar days before permit expires
S10	Spill Plan	1/permit cycle	180 calendar days after permit effective date
S11.	Slug Discharge Control Plan	1/permit cycle	180 calendar days after permit effective date
G7.	Application for permit renewal	1/permit cycle	60 calendar days before permit expires

SPECIAL CONDITIONS

S1. DISCHARGE LIMITATIONS

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a concentration in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on the effective date and lasting through the expiration date of this permit, the Permittee is authorized to discharge all process wastewater - except for untreated "stick water"*- from its fish meal processing plant into the Grays Harbor Paper LP (GHP) sewer system, subject to the following limitations:

1. GHP continues to accept the wastewater;
2. OP refrains from discharging** any process wastewater into the City of Hoquiam's *** sewer system; and,
- 3.

Effluent Limitations at Ocean Protein's Plant

Parameter	Average Monthly ^a	Maximum Daily ^b
NH ₃	400 Lbs./day	750 Lbs./day
Oil and Grease	9 Lbs./day	19 Lbs./day
	Minimum	Maximum
pH	6 SU	9 SU
^a The average monthly effluent limitation is defined as the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month, divided by the number of daily discharges measured during that month. ^b The maximum or minimum daily effluent limitation is defined as the highest or lowest allowable daily discharge. The daily discharge means the discharge of a pollutant measured during a calendar day. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day.		

* "Stick water" is the term for wastewater collected from the fish after cooking, pressing, and processing through the tricanter; it is usually processed through a series of evaporators. The processed solids become concentrated; they are added back to the fishmeal processing line. The Permittee shall collect and isolate the stick water and find an acceptable method of treatment and disposal when the evaporators are off-line. This permit does not authorize disposal of untreated stick water as defined above, or any other material, at sea. The Permittee must keep records of when the stick water evaporators are off line.

** Ocean Protein's process wastewater connection to the City of Hoquiam wastewater treatment system must be disconnected by the effective date of this proposed state permit.

*** The temporary permit allowing discharge of process wastewater from the OP fish processing plant into the City of Hoquiam's wastewater treatment system becomes null and void on the effective date of this permit. This state permit replaces the temporary permit Ecology issued on September 23, 2005.

S2. MONITORING REQUIREMENTS**A. Wastewater Monitoring**

The Permittee shall monitor the wastewater and production according to the following schedule:

Parameter	Units	Sample Point	Sampling Frequency	Sample Type
Flow	MGD	Effluent	Continuous	Recorded
BOD ₅	mg/l	Effluent	Daily	24 Hr Composite
TSS	mg/l	Effluent	Daily	24 Hr Composite
pH	SU	Effluent	Continuous	Recorded
NH ₃	mg/l	Effluent	Daily	24 Hr Composite
TKN	mg/l	Effluent	Monthly	24 Hr Composite
Oil & Grease	mg/l	Effluent	Weekly for one month, then monthly thereafter	Grab
Production	Tons/day	Fish waste intake	Continuous	Records

- Continuous means uninterrupted except for brief lengths of time for calibration, for power failure, or for unanticipated equipment repair or maintenance. Sampling shall be taken every four hours when continuous monitoring is not possible.
- To satisfy the monitoring requirements, the Permittee may use Grays Harbor Paper, LP's analyses performed on the Ocean Protein, LLC wastewater samples.
- The effluent is defined as the point of discharge into the GHP sewer system.

B. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the water and wastewater monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 or to the latest revision of *Standard Methods for the Examination of Water and Wastewater* (APHA), unless otherwise specified in this permit or approved in writing by the Department of Ecology (Department).

C. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements is consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three years.

D. Laboratory Accreditation

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 WAC. Flow, temperature, settleable solids, turbidity, pH, and internal process control parameters are exempt from this requirement. Measurements of pH shall be accredited if the laboratory must otherwise be registered or accredited. Crops, soils and hazardous waste data are exempted from this requirement pending accreditation of laboratories for analysis of these media by the Department.

S3. REPORTING AND RECORDKEEPING REQUIREMENTS

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

A. Reporting

The first monitoring period begins on the effective date of the permit. Monitoring results shall be submitted monthly. Monitoring data obtained during the previous month shall be summarized and reported on a form provided, or otherwise approved, by the Department, and be received no later than the 15th day of the month following the completed reporting period, unless otherwise specified in this permit. The report(s) shall be sent to the Department of Ecology, Industrial Section, P O Box 47706, Olympia, WA 98504-7600.

Discharge Monitoring Report forms must be submitted monthly whether or not the facility was discharging. If there was no discharge or the facility was not operating during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

B. Records Retention

The Permittee shall retain records of all monitoring information for a minimum of three years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. This period of retention shall be

extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee, or when requested by the Director.

C. Recording Results

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling; (2) the name of the individual who performed the sampling or measurement, (3) the dates the analyses were performed; (4) the name of the person who performed the analyses, (5) the analytical techniques or methods used, and (6) the results of all analyses.

D. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Condition S2. of this permit, then the results of this monitoring shall be included in calculation and reporting of the data submitted in the Permittee's self-monitoring reports.

E. Noncompliance Notification

In the event the Permittee is unable to comply with any of the permit terms and conditions due to any cause, the Permittee shall:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the violation, and correct the problem;
2. Repeat sampling and analysis of any violation and submit the results to the Department within 30 days after becoming aware of the violation;
3. Immediately* notify the Department and Grays Harbor Paper, LP's treatment plant manager of the failure to comply; and
4. Submit a detailed written report to the Department within thirty days (5 days for upsets and bypasses), unless requested earlier by the Department. The report should describe the nature of the violation, corrective action taken and/or planned, steps to be taken to prevent a recurrence, results of the resampling, and any other pertinent information.

* "Immediately notify" means within one hour for any spill, overflow, and bypass from any portion of the collection or treatment system, or for any condition that endangers human health or the environment. "Immediately" means within thirty (30) days, for any other condition.

Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit nor from resulting liability for the permittee's failure to comply.

F. Spill Notification

The Permittee shall notify Grays Harbor Paper immediately (as soon as discovered) of all discharges that could cause problems to the GHP, such as process spills and unauthorized discharges (including slug discharges).

G. Maintaining a Copy of This Permit

A copy of this permit shall be kept at the facility and must be made available to Ecology inspectors upon request.

S4. OPERATION AND MAINTENANCE

The Permittee shall at all times be responsible for the proper operation and maintenance of any facilities or systems of control installed to achieve compliance with the terms and conditions of the permit.

A. Bypass Procedures

The Permittee shall immediately notify the Department and Grays Harbor Paper, LP of any spill, overflow, or bypass from any portion of the collection or treatment system.

The bypass of wastes from any portion of the treatment system is prohibited unless one of the following conditions (1, 2, or 3) applies:

1. **Unavoidable Bypass**—Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.

If the resulting bypass from any portion of the treatment system results in noncompliance with this permit the Permittee shall notify the Department and Grays Harbor Paper, LP in accordance with condition [S3.E] “Noncompliance Notification.”
2. **Anticipated Bypass That Has the Potential to Violate Permit Limits or Conditions**—Bypass is authorized by an administrative order issued by the Department. The Permittee shall notify the Department and Grays Harbor Paper, LP at least thirty (30) days before the planned date of bypass. The notice shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The Department will consider the following prior to issuing an administrative order:
 - a. Whether the anticipated bypass is necessary to perform either construction or maintenance-related activities essential to meet the requirements of the permit.
 - b. Whether feasible alternatives to bypass are available, such as: the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.

- c. Whether the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After considering of the above circumstances and the adverse effects of the proposed bypass and any other relevant factors, and after consulting with Grays Harbor Paper, LP, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible.

Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.120.

3. Bypass For Essential Maintenance Without the Potential to Cause Violation of Permit Limits or Conditions -- Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of the permit, a violation of a pretreatment standard or requirement, or to adversely impact public health as determined by the Department prior to the bypass.

B. Best Management Practices\Pollution Prevention Program

The Permittee shall develop a Pollution Prevention Program to prevent spills to the Grays Harbor Paper, LP wastewater treatment system. The Spill Control Plan shall be developed and submitted to Ecology as specified in Special Condition [S10].

S5. PROHIBITED DISCHARGES

A. General Prohibitions

The Permittee shall not introduce into the Grays Harbor Paper, LP pollutant(s) sewer line which causes Pass Through or Interference.

B. Specific Prohibitions

In addition, the following shall not be introduced into the Grays Harbor Paper, LP wastewater treatment or discharge system:

1. Pollutants which create a fire or explosion hazard in the Grays Harbor Paper, LP sewer line, including, but not limited to, waste streams with a closed cup flashpoint of less than 60°C (140°F) using the test methods specified in 40 CFR 261.21.
2. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the Grays Harbor Paper, LP sewer line resulting in interference;
3. Any pollutant, including oxygen demanding pollutants (BOD, etc.), released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the Grays Harbor Paper, LP treatment system;

4. Heat in amounts which will inhibit biological activity in the Grays Harbor Paper, LP treatment system resulting in interference, but in no case heat in such quantities that the temperature at GHP's treatment plant exceeds 40°C (104°F) unless Ecology, upon request of GHP, approves alternative temperature limits;
5. Petroleum oil, fish oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
6. Pollutants which result in the presence of toxic gases, vapors, or fumes within the Grays Harbor Paper, LP sewer line or wastewater treatment system in a quantity that may cause acute worker health and safety problems;
7. Any trucked or hauled pollutants, except at discharge points designated by Grays Harbor Paper, LP.
8. Pollutants which will cause corrosive structural damage to the Grays Harbor Paper, LP treatment system, but in no case discharges with pH lower than 5.0 or greater than 11.0, unless the works is specifically designed to accommodate such discharges.

C. Prohibited Unless Specially Approved

1. Any of the following discharges are prohibited unless approved by the Department under extraordinary circumstances (such as a need to augment sewage flows due to septic conditions):
 - a. Noncontact cooling water in significant volumes.
 - b. Storm water and other direct inflow sources.
 - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment or would not be afforded a significant degree of treatment by the system.
2. Unless specifically authorized in this permit, the discharge of dangerous wastes defined in Chapter 173-303 WAC, is prohibited.

S6. DILUTION PROHIBITED

The Permittee shall not dilute the wastewater discharge with stormwater or increase the use of potable water, process water, noncontact cooling water, or, in any way, attempt to dilute an effluent as a partial or complete substitute for adequate treatment to achieve compliance with the limitations contained in this permit.

S7. SOLID WASTE DISPOSAL

A. Solid Waste Handling

The Permittee shall handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground water and surface water.

B. Leachate

The Permittee shall not allow leachate from its solid waste material to enter state waters without first providing all known, available and reasonable methods of treatment, nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee shall apply for a permit or permit modification as may be required for such discharges to state ground waters or surface waters.

C. Solid Waste Control Plan

The Permittee shall submit a solid waste control plan to the Department no later than 180 days after the effective date of the permit. This plan shall include all solid wastes with the exception of those solid wastes regulated by the Dangerous Waste Regulations (Chapter 173-303 WAC). The solid waste handling plan shall include at a minimum: a description of these solid wastes, their source, Ocean Protein's generation rate, and disposal methods. This plan shall not be at variance with any approved local solid waste management plan. Any proposed revision or modification of the solid waste handling plan must be submitted to the Department. The Permittee shall comply with the plan and any subsequent modifications thereof. The Permittee shall submit an update of the solid waste control plan with the application for permit renewal sixty (60) calendar days prior to the expiration date of this permit.

S8. DUTY TO REAPPLY

The Permittee must apply for permit renewal 60 days before the expiration of the permit.

S9. NON-ROUTINE AND UNANTICIPATED DISCHARGES

Beginning on the effective date of this permit, the Permittee may discharge non-routine wastewater on a case-by-case basis if approved by the Department. Prior to any such discharge, the Permittee shall contact the Department and **at a minimum** provide the following information:

1. The nature of the activity that is generating the discharge.
2. Any alternatives to the discharge, such as reuse, storage or recycling of the water.
3. The total volume of water expected to be discharged.
4. The results of the chemical analysis of the water. The water shall be analyzed for all constituents limited for the Permittee's discharge. The analysis shall also include hardness, any metals that are limited by water quality standards, and any other parameter deemed necessary by the Department. All discharges must comply with the effluent limitations as established in Condition S1 of this permit, and any other limitations imposed by the Department.
5. The date of proposed discharge and the rate at which the water will be discharged, in gallons per minute.

Comment [DoE1]: The permit writer should specify any other known or suspected pollutants here.

The discharge cannot proceed until the Department has reviewed the information provided and has authorized the discharge. Authorization from the Department will be by letter to the Permittee or by an Administrative Order by the Department after consulting with Grays Harbor Paper, LP.

S10. SPILL PLAN

Within six months after the effective date of the permit, the Permittee shall submit to the Department a spill control plan for the prevention, containment, and control of spills or unplanned releases. The Permittee shall review the plan at least annually and update the Spill Plan as needed. Changes to the plan shall be sent to the Department. The plan and any supplements shall be followed throughout the term of the permit.

The updated spill control plan shall include the following:

1. A description of operator training to implement the plan.
2. A description of the reporting system which will be used to alert responsible managers and legal authorities in the event of a spill.
3. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) which prevent, contain, or treat spills of these materials.
4. A list of all oil and petroleum products, materials, which when spilled, or otherwise released into the environment, are designated Dangerous (DW) or Extremely Hazardous Waste (EHW) by the procedures set forth in WAC 173-303-070, or other materials which may become pollutants or cause pollution upon reaching state's waters.

Plans and manuals required by 40 CFR Part 112, contingency plans required by Chapter 173-303 WAC, or other plans required by other agencies which meet the intent of this section may be submitted.

S11. SLUG DISCHARGE CONTROL PLAN

The Permittee may combine Spill Plan as described in S10. with the slug discharge control plan described in this section.

On or before 180 calendar days after the effective date of the permit, the Permittee shall prepare and submit to the Department a plan to minimize the potential of slug discharges from Ocean Protein. The plan and any subsequent revisions shall become effective 30 calendar days following submittal. Such plan shall include the following information and procedures relating to the prevention of unauthorized slug discharges:

1. A description of a reporting system to be used to immediately notify Grays Harbor Paper, LP operator, and appropriate state, federal, and local authorities of any slug discharges, and provisions to provide a written follow-up report within five days;
2. A description of operator training, equipment, and facilities (including overall facility plan) for preventing, containing, or treating slug discharges;

3. A list of all raw materials, products, chemicals, and hazardous materials used, processed, or stored at the facility; the normal quantity maintained on the premises for each listed material; and a map showing where they are located.
4. A description of discharge practices for batch and continuous processes under normal and non-routine circumstances;
5. A brief description of any unauthorized discharges which occurred during the 36-month period preceding the effective date of this permit and subsequent measures taken by Permittee to prevent or to reduce the possibility of further unauthorized discharges; and
6. An implementation schedule including additional operator training and procurement and installation of equipment or facilities required to properly implement the plan.

The Permittee shall review its slug discharge plan and update it as needed but no less than every two years. All revisions or updates of this plan shall be submitted to and approved by the Department. The current approved plan shall be maintained on the plant site and be readily available to facility personnel. The Permittee shall submit an update of the slug discharge control plan, or a certification that it is current with the application for permit renewal.

S12. RECORDS OF WASTE TRANSPORTED OFF-SITE

The Permittee shall maintain detail records of all wastes transported off-site for disposal. This applies to all wastes not authorized previously defined in the permit including “stick water” collected when the evaporators are off-line. The Permittee must keep records of when the “stick water” evaporators are off line. The name, address, and phone number or the contractor(s) and the licensed entity authorized to accept, treat, and dispose of the waste will be recorded and submitted each month with the monthly discharge monitoring report.

GENERAL CONDITIONS

G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Department shall be signed as follows:

- A. All permit applications shall be signed by a general partner or his delegate.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by the person described above and is submitted to the Department at the time of authorization, and
 - 2. The authorization specifies either a named individual or any individual occupying a named position.
- C. Changes to authorization. If an authorization under paragraph B.2. above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

G2. RIGHT OF ENTRY

Representatives of the Department shall have the right to enter at all reasonable times in or upon any property, public or private, for the purpose of inspecting and investigating conditions relating to the pollution or the possible pollution of any waters of the state. Reasonable times shall include normal business hours; hours during which production, treatment, or discharge occurs; or times when the Department suspects a violation requiring immediate inspection. Representatives of the Department shall be allowed to have access to, and copy at reasonable cost, any records required to be kept under terms and conditions of the permit; to inspect any monitoring equipment or method required in the permit; and to sample the discharge, waste treatment processes, or internal waste streams.

G3. PERMIT ACTIONS

This permit shall be subject to modification, suspension, or termination, in whole or in part by the Department for any of the following causes:

- A. Violation of any permit term or condition;
- B. Obtaining a permit by misrepresentation or failure to disclose all relevant facts;
- C. A material change in quantity or type of waste disposal;
- D. A material change in the condition of the waters of the state; or
- E. Nonpayment of fees assessed pursuant to RCW 90.48.465.

The Department may also modify this permit, including the schedule of compliance or other conditions, if it determines good and valid cause exists, including promulgation or revisions of regulations or new information.

G4. REPORTING A CAUSE FOR MODIFICATION

The Permittee shall submit a new application, or a supplement to the previous application, along with required engineering plans and reports, whenever a new or increased discharge or change in the nature of the discharge is anticipated which is not specifically authorized by this permit. This application shall be submitted at least 60 days prior to any proposed changes. Submission of this application does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

G5. PLAN REVIEW REQUIRED

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications should be submitted at least 180 days prior to the planned start of construction. Facilities shall be constructed and operated in accordance with the approved plans.

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES

Nothing in the permit shall be construed as excusing the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. PERMIT TRANSFER

This permit is automatically transferred to a new owner or operator if:

- A. A written agreement between the old and new owner or operator containing a specific date for transfer of permit responsibility, coverage, and liability is submitted to the Department;
- B. A copy of the permit is provided to the owner and the receiving treatment system and;
- C. The Department does not notify the Permittee of the need to modify the permit.

Unless this permit is automatically transferred according to section A. above, this permit may be transferred only if it is modified to identify the new Permittee and to incorporate such other requirements as determined necessary by the Department.

G8. REDUCED PRODUCTION FOR COMPLIANCE

The Permittee shall control production or discharge to the extent necessary to maintain compliance with the terms and conditions of this permit upon reduction of efficiency, loss, or failure of its treatment facility until the treatment capacity is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power for the treatment facility is reduced, lost, or fails.

G9. REMOVED SUBSTANCES

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the effluent stream for discharge.

G10. PAYMENT OF FEES

The Permittee shall submit payment of fees associated with this permit as assessed by the Department. The Department may revoke this permit if the permit fees established under Chapter 173-224 WAC are not paid when due.

G11. PENALTIES FOR VIOLATING PERMIT CONDITIONS

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be deemed a separate and distinct violation.